

October 13, 2014

EPL 11797

<http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=9622&SYSUID=1&LICID=11797>

Test date: September 11, 2014  
Date results received: October 3, 2014

POINT 3 – CO-GENERATION EXHAUST STACK

Parameter	Unit of Measure	Frequency	Lower Limit	Averaging Period	Result
Nitrogen Oxides	mg/m <sup>3</sup>	Yearly	450	1-hour	400
Volatile Organic Compounds	mg/m <sup>3</sup>	Yearly	40	1-hour	0.16
Sulfuric Acid mist and Sulfur Trioxide	g/m <sup>3</sup>	Yearly	0.1	1-hour	0.1