

September 30, 2015

EPL 11797

<http://www.environment.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=9622&SYSUID=1&LICID=11797>

Test date: August 20, 2015
Date results received: September 30, 2015

POINT 3 – CO-GENERATION EXHAUST STACK

Parameter	Unit of Measure	Frequency	Lower Limit	Averaging Period	Result
Nitrogen Oxides	mg/m ³	Yearly	450	1-hour	380
Volatile Organic Compounds	mg/m ³	Yearly	40	1-hour	0.14
Sulfuric Acid mist and Sulfur Trioxide	g/m ³	Yearly	0.1	1-hour	0.051