

July 7, 2016

EPL 11797

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=70413&SYSUID=1&LICID=11797>

Sample date: June 6, 2016
Date results received: June 27, 2016

POINT 7 – DISCHARGE CONTROL PIT

Parameter	Unit of Measure	Frequency	Limit	Averaging Period	Result
Biochemical oxygen demand	milligrams per litre	Per release	20		5
Conductivity	microsiemens per centimetre	Per release	1500		45
Nitrogen (ammonia)	milligrams per litre	Per release	1.0		<0.5
pH	pH	Per release	6.5-8.5		6.81
TSS	milligrams per litre	Per release	50		2