

December 12, 2018

EPL 11797

<http://www.epa.nsw.gov.au/prpoeoapp/Detail.aspx?instid=11797&id=11797&option=licence&searchrange=licence&range=POEO%20licence&pr=no&status=Issued>

Test date: October 3, 2018
Date results received: December 12, 2018

POINT 3 – CO-GENERATION EXHAUST STACK

Parameter	Unit of Measure	Frequency	Lower Limit	Averaging Period	Result
Nitrogen Oxides	mg/m ³	Yearly	450	1-hour	310
Volatile Organic Compounds	mg/m ³	Yearly	40	1-hour	0.07
Sulfuric Acid mist and Sulfur Trioxide	g/m ³	Yearly	0.1	1-hour	0.0036