

March 5, 2020

EPL 11797

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=70413&SYSUID=1&LICID=11797>

Sample date: February 10, 2020
Date results received: February 26, 2020

POINT 7 – DISCHARGE CONTROL PIT

Parameter	Unit of Measure	Frequency	Limit	Averaging Period	Result
Biochemical oxygen demand	milligrams per litre	Per release	20		<5
Conductivity	microsiemens per centimetre	Per release	1500		66
Nitrogen (ammonia)	milligrams per litre	Per release	1.0		<0.5
pH	pH	Per release	6.5-8.5		7.08
TSS	milligrams per litre	Per release	50		6