

March 22, 2022

EPL 11797

<http://www.epa.nsw.gov.au/prpoeoapp/ViewPOEOLicence.aspx?DOCID=70413&SYSUID=1&LICID=11797>

Sample date: March 8, 2022  
Date results received: March 22, 2022

POINT 7 – DISCHARGE CONTROL PIT

Parameter	Unit of Measure	Frequency	Limit	Averaging Period	Result
Biochemical oxygen demand	milligrams per litre	Per release	20		<5
Conductivity	microsiemens per centimetre	Per release	1500		5
Nitrogen (ammonia)	milligrams per litre	Per release	1.0		<0.5
pH	pH	Per release	6.5-8.5		6.5
TSS	milligrams per litre	Per release	50		<1